

From: Neil Garrett Neil.Garrett@occ.ok.gov
Subject: Facility #55-03490: Former Fina Station #9442, 900 S Broadway, Edmond, OK 73034
Date: April 28, 2021 at 1:21 PM
To: heather@dakil.com

NG

To Whom it concerns,

Three underground storage tanks were pulled from the ground on 3/1/1989. Enough backfill was removed from the top and sides of the tanks to allow extraction. All of that backfill was hauled off and disposed of offsite. The tanks had only held gasoline and soil sampling indicated they had leaked. Case 064-O4 was activated on 4/10/1989 and the subsurface investigated and groundwater monitored. A risk assessment was performed and determined that only acceptable gasoline concentrations remained. Most remaining gasoline impact is associated with the former tank pit and not much underlies the existing building. The case was closed 7/14/1998.

Sincerely,

Neil R. Garrett

**Project Environmental Analyst Supervisor
Okla. Corp. Comm./Petroleum Storage Tank Div.
2101 N. Lincoln Blvd.
Oklahoma City, OK 73105**

E-mail: neil.garrett@occ.ok.gov

Phone: (405) 522-5266

Mobile: (405) 556-1829

Fax: (405) 521-4945

 **Please consider the environment before printing this e-mail.**